

Fax Cover Sheet

FISHER-ROSEMOUNT

Rosemount Instruments

Suite 100, 8702 - 48 Avenue
EDMONTON AB T6E 5L1
Tel: 1-403-465-0446

x. 357

PAGES TO FOLLOW 0

DATE 97-10-15 TIME 3:43 PM

TO	
NAME	Stephen Schultz
COMPANY	Royal Oak Mines
LOCATION	Yellowknife
FAX NO.	403-873-2914
CC	
SUBJECT	Instrument Air Quality

FROM	
SENDER	Chris Martin
DEPT.	Sales Account Rep
PHONE NO.	(403) 951-2860
FAX NO.	(403) 465-0440
FAX REF. NO.	

Stephen;

Moisture dewpoint should be -40 Celcius. Oil concentration in the air should be less than 0.1 ppm hydrocarbons. You will need to condense, coalesce, and carbon absorb or dessicant absorb to remove any oil or water from the air supply to the Rosemount system.

Hope this helps you.
Chris

Swair.
-D Peter Ceesse - October 27